

Emilio Songco, Jr.

From: Mohammad Karim [MKarim@oshpd.state.ca.us]
Sent: Monday, October 26, 2009 2:34 PM
To: Jr. Emilio Songco
Cc: Chris Tokas
Subject: RE: Special Preapproval by Static Testing for Isolators
Attachments: 2-1708A.5 rev 3.pdf

Don:

We will be more than happy to approve CalDyn Isolator/Restraints as part of the equipment approval, for which test is performed in accordance ICC-ES AC 156. CAN 2-1708A.5 Section 4.2 address how components can be substituted by equivalent product, when it become necessary ("The components from the mounting brackets to the supporting structure shall have the similar flexibility and strength to what is used in the equipment qualification test and may be qualified by a supporting analysis.").

If you still have questions please feel free to call me.

Regards

Karim

M. R. Karim, Ph. D., S. E.
District Structural Engineer
OSHPD Facilities Development Division
400 R Street, Suite 200
Sacramento, CA 95811-6213
E-Mail: MKarim@oshpd.ca.gov
Ph. 916-440-8410
Fax. 916-324-9187

P. S. Due to the unprecedented statewide fiscal crisis and in response to Governor's Executive Order S-13-09, OSHPD's offices will be closed the first three Fridays each month beginning July 10, 2009 and ending June 30, 2010.

>>> "Emilio Songco, Jr." <caldyn@earthlink.net> 10/26/2009 3:43 PM >>>
Please see attached.

Thank you,
Don Benkert

From: Mohammad Karim [mailto:MKarim@oshpd.state.ca.us]

10/26/2009