



CALIFORNIA DYNAMICS CORP.
 5572 ALHAMBRA AVE.
 LOS ANGELES, CA. 90032-3106

CALL US - TO SET THINGS RIGHT
 PH (323) 223 - 3882
 FAX (323) 223 - 7941
 email: caldyn@earthlink.net

RENEWED
 California Office of Statewide
 Health Planning and Development
FIXED EQUIPMENT ANCHORAGE
R-0070 June 15, 1998
 *Valid for 3 Years Maximum




Terence Fong (916) 654-3362

R-0070 PRE-APPROVAL
GENERAL NOTES
 TYPES QSL & JQ
 ISOLATOR RESTRAINTS
 FILE 130

NOTE: Instead of issuing newly dated stamps, OSHPD confirms current validity on their website as follows:
http://www.oshpd.cahwnet.gov/fdd/About_Us/Organization/Policy_and_Planning/Contract_mngmt/Anchorage-Pre-Approvals/PreApprovalList.pdf

JOB: _____
 CUST: _____
 ENG'R: _____
 TAG: _____



General Notes for CalDyn Types **QSL** and **JQ** Isolator Restraints

1. Only the Isolator Restraint is Pre-Approved. The following items are not included in this Pre-Approval :
 - a. Connection between the equipment and the Isolator Restraint.
 - b. Connection between the Isolator Restraint and the support structure.

2. The Engineer (or Architect) of Record shall submit :
 - a. Details and Calculations of the connection between the equipment and the Isolator Restraint.
 - b. Details and Calculations of the connection between the Isolator Restraint and the support structure.
 - c. Calculations verifying the adequacy of the Isolator Restraint considering horizontal and vertical forces acting simultaneously through the equipment C.G..
