



CALIFORNIA DYNAMICS CORP.

LOS ANGELES, CA. 90032-3106

PH (323) 223 - 3882

FAX (323) 223 - 7941

email: caldyn@earthlink.net

APPROVED
Fixed Equipment Anchorage
Office of Statewide Health Planning and Development



OPA-0070

on Wednesday, December 01,
2004

**** Valid for 3 Years Maximum ****


John D. Gillengerten
John D. Gillengerten (916)654-3547

TYPE **RL-A**
SEISMIC RESTRAINT
CALIF. PRE-APPROVED
OPA - 0070

FILE 120

11/08/04

INTERACTION CURVE



NOTICE
121 File page describing
PRE-APPROVAL USE
and applicable **NOTES**
is included in this
OPA-0070 **PRE-APPROVAL**



ALLOWABLE STRESS DESIGN		
MECHANICAL AND ELECTRICAL COMPONENTS COEFFICIENTS		
Mechanical and Electrical Component or Element	Component Amplification Factor a_p	Component Response Modification Factor R_p
HVAC System Vibration Isolated	2.5	1.5
General Electrical Equipment	2.5	1.5

RLA Maximum clearance not greater than 1/4 inch
Design force may be taken as F_p

