

**TYPICAL CALLOUT**

Type	Maximum Load
SSK E 415 (no anchor holes)	
SSKA E 415 (w/anchor holes)	
	Deflection Code


+ The ratio of the spring diameter to its height at rated deflection is not under .8 and extra deflection is not less than 50%.

Operation Height may equal Free Height depending upon load and adjustment.

ID numbers are multi-purpose. They identify the products as well as the deflection rating in inches and load rating in pounds. For example: E415 indicates 1 inch deflection rating and 415 pounds load rating for the SSK 415.

For compact support of heavy loads many SSK's include inner springs. For low profile support of heavy loads, many SSK's have clustered springs.

Installation Instructions  
See file F33



Isolator Locations	Isolator Selections

**1 Inch Deflection Rating**

ID Numbers	W	S	F	X	RD	Free HT.
E21, E55, E79, E106 E143, E187, E244, E318, E415	2	5	3-1/2	2	3/8NC	4-1/4
ET473, ET667	4	7	5-1/2	4	1/2NC	4-1/2
ET940, ET1326, E1660 E2000, E2532, E3204					5/8NC	5-1/8
E3735, E4500, E5697, E7209	6	9	7-1/2	6	3/4NC	5-1/2

**2 Inch Deflection Rating**

ID Numbers	W	S	F	X	RD	Free HT.
FT30, FT41, FT60, FT85 FT121	3	6	4-1/2	2-1/2	1/2NC	5-1/2
FT171, FT241, F348, F453 F590, F676, F787, F918				3		6-1/2
F1159, F1408, F1710	4	7	5-1/2	4	5/8NC	8-1/8
F2360, F2704, F3148, F3672	6	9	7-1/2	6	3/4NC	7
F4077, F5310, F6084, F7083, F8262	9	12	10-1/2	9	7/8NC	7-1/2

**3 Inch Deflection Rating**

ID Numbers	W	S	F	X	RD	Free HT.
G213, G303	3	6	4-1/2	3	1/2NC	8-1/4
G426, G606		10	8-1/2	7	5/8NC	
G853, G1223		7	5-1/2	4		
G1706, G2446	4	12	10-1/2	9	3/4NC	9-3/8
G3412, G4892	8	11	9-1/2	8	7/8NC	9-7/8
G5971, G7677	12	15	13-1/2	12	1-NC	10
G11007					10-1/4	

**4 Inch Deflection Rating**

ID Numbers	W	S	F	X	RD	Free HT.
H154, H221	4	7	5-1/2	4	1/2NC	8-7/8
H308, H442		11	9-1/2	8		
H624, H883	5	8	6-1/2	5	5/8NC	11
H1248, H1766		14	12-1/2	11	3/4NC	11-1/4
H2496, H3532	10	13	11-1/2	10	7/8NC	11-1/2
H4368, H5616	14	17	15-1/2	14	1-NC	11-3/4
H7947	15	18	16-1/2	15	1-1/8NC	12

**CALDYN**  
CALIFORNIA DYNAMICS CORPORATION  
5572 ALHAMBRA AVE. LOS ANGELES CA, 90032  
PH. 323-223-3882 FAX. 323-223-7941  
email: caldyn@earthlink.net  
"CALL US - TO SET THINGS RIGHT"  
Assoc. Member

JOB: \_\_\_\_\_

CUSTOMER: \_\_\_\_\_

TAG: \_\_\_\_\_

Dwg. No. **F551** Date **9/20/16**

PREP By: \_\_\_\_\_ Date \_\_\_\_\_

CHKD By: \_\_\_\_\_ Date \_\_\_\_\_

**DO NOT SCALE DRAWING**

TYPE

**SSK**  
**SSKA**

SPRING ISOLATOR  
BARE, UNHOUSED